



Renton Regional Fire Authority

Electronic Monitoring Installation

1055 S. Grady Way, Renton, WA 98057
425-430-7024

OFFICIAL USE ONLY	
Project #:	_____
Permit #: F	_____

**** All requested items must be provided in order to process this application. ****

Building Permit #(s): _____ Number of Tenants/Buildings: _____

Property Address
(include Bldg #/Suite/Column/etc.): _____

Description of Work
to be Performed: _____

Value of Construction: \$ _____ Boeing Job # (if applicable): _____

Property Owner: _____ Phone: _____

Street Address: _____ City/State: _____ Zip: _____

Contractor: _____ Contact Person: _____

Phone: _____ Fax: _____ Email: _____

Street Address: _____ City/State: _____ Zip: _____

State Contractor's License #: _____ Renton Business License #: _____

Tenant Name: _____ Suite/Room: _____

CONTRACTOR INFORMATION:
An Electrical Permit is required to be obtained through the Building Department prior to the issuance of the Electronic Monitoring Permit.
Electrical Permit # _____

I certify that the information furnished by me on this application is true and correct and that the applicable requirements of the City of Renton will be met. I understand that this application is valid for six months from the application date. If a permit is not issued during this time period, this application will become void. This application does not constitute a permit to work. Work is not to commence until the permit is posted on premises where work is to be performed. Certification is hereby rendered that no work will be done except as described, and that all work will conform to the applicable codes.

Applicant Signature: _____ Date: _____



Renton Regional Fire Authority

Guidelines for Electronic Monitoring for Hazardous Materials Systems

Separate plans and permits are required for installation of electronic monitoring systems for hazardous materials systems as required by International Fire Code and City of Renton Ordinance. Submit an electronic copy of this application along with plans, cut sheets, calculations and applicable specifications for review. Hard copy paper plans are not acceptable in any case. All information related to the installation shall be included with the plan review package. A plan review fee is to be paid at the time the plans are submitted, based on the value of the work to be performed. All information and evidence of required licenses are to be provided with the application for permit. All contractors doing work in the City of Renton are required to have a Renton Business License. If the installation is in conjunction with a building permit, the **Building Permit Number** shall be provided at the time of submittal. The **City assigned** street address must be included on the application. The following specific information is required for this application:

1. A brief, well-written project narrative describing the full extent of the proposed systems' capabilities
2. Manufacturers' specification sheets on all proposed equipment and listing on equipment, to include low level alarms, high level alarms, leak detection alarms, local beacons, audible and/or remote monitoring.
3. The plans must include location of visual local beacons, decibel level of audible and any description of proposed association to a 24-hour monitoring service.
4. A test procedure document which clearly defines the methods, materials and procedures necessary to perform a confidence test
5. A data sheet which certifies the system meets or exceeds the required design minimum when the system is tested
6. The occupant will be responsible for annual confidence testing. The minimum design standards are to incorporate the occupant's annual confidence testing requirements. (Design and build the system so it can be tested annually.)

All field tests and/or inspections must be scheduled a **minimum of 24 hours** prior to inspection. Inspection appointments will be subject to the availability of personnel. The contractor must be present at the time of all field tests.

Questions regarding these Guidelines should be directed to:

Renton Regional Fire Authority

425-430-7024