



RENTON REGIONAL FIRE AUTHORITY

Office of the Fire Marshal

(425) 430-7043

TENT FOOD BOOTH REQUIREMENTS

To insure proper installation and location of cooking appliances and exiting from tent areas, all food booths shall meet the requirements outlined herein.

A self-inspection of the vendor area shall be conducted by the vendor PRIOR to operating.

ENCLOSED TENTS: EXITING

An exit from the rear of the tent must be a minimum of 36-inches in width. A clear unobstructed aisleway to the exit from all portions of the tent shall be maintained at all times.

Heating and cooking appliances shall not be located within 10-feet of exits nor within 12" of tent walls.

FIRE EXTINGUISHERS REQUIREMENTS IN TENTS

Fire extinguishers shall be provided in every tent or canopy as follows:

*200 to 500 square feet of floor area:	One (1) 2A10BC
*501 to 1,000 square feet of floor area:	Two (2) 2A10BC
*Kitchen area where flammable or combustible liquids are used or deep fat frying is conducted:	One (1) Type K

Fire extinguishers shall be currently serviced with a service tag attached and located in an easily accessible location.

HEATING/COOKING APPLIANCES

LPG fuel containers used for cooking appliances shall not be stored inside of tents. Tanks must be stored outside of tents, and be secured and placed in a location to avoid possible vehicle damage.

Deep fat frying is prohibited within tents.

VEHICLE PARKING

Vehicles may be parked behind tents **TEMPORARILY** to load and unload supplies. At any other time, vehicles will be required to be parked in an approved parking location.

Thank you for working with the Renton Regional Fire Authority to ensure a fire safe event.